





Werkzeuge für Arbeiten unter Spannung

Tools for live working



to whom it may concern

CERTFICATE OF CONFORMITY

A) This is to certify that all tools marked with double triangle, $1000 \text{ V} + \text{V}$	/DE GS are
manufactured in accordance with the required DIN IEC 60900 standards.	

- **B)** This is to certify that articles marked with double triangle + 1000 V (without VDE GS mark, as we have not submitted an official application for VDE certification for these articles) are also manufactured in accordance with the DIN IEC 60900 standard.
- **C)** Articles without double triangle, 1000 V or VDE GS markings do not comply with the above standard.

We certify that all above-mentioned articles (except articles mentioned under C) are produced in accordance to the standards requested DIN IEC 60900, i.e. twin triangle, 1000V. Each tool is tested 10.000V.

We confirm that the aforementioned statements are in accordance to the facts.

Remscheid, August 26, 2024

Klaus Friedrich GmbH & Co. KG

(Maddalena Annunziata)